

ADDENDUM NO. 1

Ansonia Local Schools
**SCHOOL BUS FACILITY FUEL SYSTEM UPGRADES
AND
SCHOOL BUS ENGINE & FUEL SYSTEM CONVERSIONS**

September 2, 2010

To: Planholders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331
Phone: (937) 548-7511
Fax: (937) 548-7484
E-mail: info@moteassociates.com

Re: Ansonia Local Schools
School Bus Facility Fuel System Upgrades
And School Bus Engine & Fuel System Conversions

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated August 2010. Acknowledge receipt of this Addendum in space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

1. Electrical Contractor shall furnish, install and wire 2-hour fire resistance rated motorized louver LD-1.
2. On Sheet 3, UL Design No. U336, Note #5 should read: Existing subsiding and siding to remain, no alteration.