

ADDENDUM NO. 1

VILLAGE OF ANSONIA

SANITARY & STORM SEWER SEPARATION PART A

September 9, 2009

To: Plan Holders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331
Phone: (937) 548-7511
Fax: (937) 548-7484
E-mail: info@moteassociates.com

Re: Village of Ansonia
Sanitary & Storm Sewer Separation ó Part A

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated August 2009. Acknowledge receipt of this Addendum in space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

1. The Bid Form submittal packet located in the back of each set of contract documents has been updated with additional documents. Please refer to our website for the current bid packet (35 pages) to be used in your proposal. This bid packet can be downloaded and printed from our website at: <http://www.moteassociates.com/projects.htm>. (Addendum No. 1 - Attachment 1)
2. The plans have been revised to include changes to the lift station (exhaust fan, control panel location, gasketed & sealed access and pump orientation). A high water alarm horn and strobe has also been added. Drawing copies of the revisions are attached. The full-size drawing can be reviewed and downloaded from our website at: <http://www.moteassociates.com/projects.htm>. (Addendum No. 1 - Attachment 2).
3. Davis Bacon wage rate requirements for ARRA projects are included as part of this addendum. These requirements can be downloaded and printed from our website at <http://moteassociates.com/projects.htm> (Addendum No. 1 - Attachment 3).
4. The Pump Station Replacement Specification 33 32 13 has been updated. The updated version can be downloaded and printed from our website at <http://moteassociates.com/projects.htm> (Addendum No. 1 - Attachment 4).
5. This addendum will be posted on our website (including pdf drawings of the revised plans. Please see the following link: <http://www.moteassociates.com/projects.htm>. Refer to Village of Ansonia ó Sanitary & Storm Sewer Separation Project, Addendum No. 1 including Attachments 1 thru 4.
6. The Engineer's estimate for Alternate No. 2 (*East mobile home park lift station rehabilitation*) has been adjusted to \$43,000.
7. Should you not have access to the Internet to download the required documents, please call our office at 937-548-7511 for other arrangements.