

ADDENDUM NO. 1

VILLAGE OF OHIO CITY Equipment Storage Building

November 14, 2011

To: Planholders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331
Phone: (937) 548-7511
Fax: (937) 548-7484
E-mail: info@moteassociates.com

Re: Village of Ohio City
Equipment Storage Building

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated November 2011. Acknowledge receipt of this Addendum in space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

1. The owner will install a storm outlet within 6' of the building prior to construction. It shall be the responsibility of the contractor to tie downspout tile to the outlet.
2. On sheet #6 delete keynote #6 "4" 304 aggregate base". This will be installed to finished grade prior to construction.
3. Please take note that the cast-in-place concrete must be installed per section 03 30 00, 3.01, 1, 1 & 2 of the contract documents.
4. Please see General Note #10 on sheet #1 for permitting responsibilities.

End of Addendum